Enclosure, EN-10106, Controlling ASC Serving Exhaust and Supply Fans Serving the Injection Room, B100.



PANEL MATERIAL

	DEVICE TAG	QTY	CODE NUMBER	DESCRIPTION
(P)	EN-10106	1	AS-AHU101-0	AIR HANDLING UNIT ENC/TER
		1	AS-AHU102-0	AIR HANDLING UNIT LOGIC B
		1	EN-ENC200-0	ENCLOSURE
		1	AS-XFR100-0	100VA TRANSFORMER KIT
(P)	XX-1	1	AS-RLY100-0	LINE VOLTAGE RELAY KIT

NOTES:

1. ALL MATERIAL WITH (P) PRECEEDING THE DEVICE TAG IN THE BILL OF MATERIAL IS PROPRIETARY AND IS BEING SUPPLIED BY JOHNSON CONTROLS, INC. ALL OTHER MATERIAL IS NON-PROPRIETARY.

CONTROL SYSTEM POINT OBJECTS

106 NC10_HV\SF201 AHU AHU

5	SF-201-4\SF201_S	BI
6	SF-201-4\SF202_S	BI
2	SF-201-4\SF202_FA	BI
7	SF-201-4\SF203_S	BI
3	SF-201-4\SF203_FA	BI
8	SF-201-4\SF204_S	BI
4	SF-201-4\SF204_FA	BI
1	SF-201-4\SF201_C	BO
2	SF-201-4\SF202_C	BO
3	SF-201-4\SF203_C	BO
4	SF-201-4\SF204_C	BO
1	SF-201-4\FAN-C	BO
2	NC10_SV\SF201_FA	AI
3	NC10_SV\EF205_S	AI
5	NC10_SV\EF204_S	AI
6	NC10_SV\EF203_S	AI
7	NC10_SV\EF202_S	AI
4	SF-201-4\ZN_T	AI
0	SF-201-4\SF-201	CS/ASC

FILE: EN-10106

DRAWING TITLE					
Injection Room, B100 Supply Fans, SF-201-SF-204 and Exh. Fans, EF-202-EF-205 EN-10106, AS-AHU100			RECORD	05/11/94	SF
		1	ADD DISCONNECT	07/15/92	SF
	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN DATE	BY
	SALES ENGR JP / PROJECT MGR SF / APPL. ENGR DCS	DRAWN BY SF DATE 12/12/91	APPROVED BY DATE		

PROJECT
The Argonne National Labs
Advanced Photon Source Campus
9700 Cass Avenue South
Argonne, IL 60439

JOHNSON CONTROLS
Systems & Services Division

3007 MALMO ROAD
ARLINGTON HEIGHTS
ILLINOIS 60005
708/364-1500 Main
708/806-4438 Eng

CONTRACT NUMBER 91390-0009

DRAWING NUMBER 91-9-B-06B

COPYRIGHT JOHNSON CONTROLS, INC.1993