

ACIS Software Modification for the Chain C Bypass Relay Addition

Enable Zone “n” Chain C bypass relay:

Zone F ACIS test loads connected &
Zone “n” test toggle switch enabled.

MCR and ACIS remote rack Chain C Bypass LEDs are on when any Chain C bypass is detected on.

Trip Storage Ring Zone “n” ACIS if:

The Zone “n” Chain C bypass relay is detected on, but the PLC is not enabling it.