


Card Reader / Emergency Power Update - B. Wesolowski: Cardkeys will be put on the emergency system. See the diagram below regarding emergency panel board work:



Last week some users had no access to their area because card key on LOM entrances power not on emergency power. We have UPS in location for network switches. This can be run to card key controller. The timeframe is to be determined.

Bill has looked at sources of 120VAC emergency power for drop cords for use by CATs in case of power outage. In most cases, it appears that we can consolidate to get a circuit for users. This would only be used during a power outage. We will start setting cords next week.