The Australian synchrotron

A minor status overview and pictures from down under.

Delivered by S Hunt, Occasional consultant to the AS and to many other facilities.

Richard Farnsworth and Team at the AS, who have depended on the community for support, software and assistance over the last four years.



The Australian Synchrotron uses Linux throughout Real-time Linux low down and Softer on up. Various flavours, inc Redhat and Debian.

All IOCs are Linux Based, and there is little VME hardware, except for timing and the Beamlines, where a PCI to VME bridge is used.







# initial suite of beamlines

X-ray diffraction For structural analysis of solid state structures

**Spectroscopy** For analysis of bonds and electronic organisation of molecules

#### Imaging

For high contrast imaging of objects from small animals through to engineering components and minerals

#### **Polarimetry**

For determining the secondary structure of proteins and other biological molecules

#### Micromachining

For manufacturing micro-devices with very high depth to width ratio and excellent surface finish



# **Overhead**



Australian Synchrotron site from the air, June 2006



#### From a tiger moth







Aerial view of the Australian Synchrotron with Melbourne CBD skyline Australian Synchrotron

Storage ring circumference: 216m

Electron energy: 3 GeV

Commencing operation: 2007

Initial suite of 9 beamlines


Capacity for at least 30 beamlines in the long term



The instrumentation and control system for the Synchrotron accelerator systems are built using EPICS. No other single major control systems are used, although there are pockets of things such as Labview and a few dedicated controllers. This is true for both accelerator and Beamlines. We used a combination of EDM, MEDM and our own GUI, shots follow



#### Vacuum Profile






#### 💵 Yacuum Control - 1

Framework General Vacuum Magnets & PS Diagnostics Timing Miscellaneous

		I	/acuum Contr	ol - Sector 1			- (†
Select by Sector			Pumps and Gauges			Storage Ring Vacuum Sta	atus
			Name	Status	Pressure	Straight	0k
01 02 03 04 05	06 07 08 09	10 11 12 13 14	Pirani Arc	Low	1.0E-03 mbar	Arc	0k
Valve Control			Pirani Straight	Low	1.0E-03 mbar	Front End 1 Vacuum State	us
	Valve 1	Valve 2					
Open/Close Status	Opened	Opened	Cold Cathode Arc 1	0k	2.1E-09 mbar		
Allow Open	Enabled	Enabled	Cold Cathode Arc 1			Front End 2 Vacuum State	
o 101 o			Cold Cathode Straight	0k	1.4E-09 mbar 0.0E+00 mbar		
Open/Close Setpoint	No Action	No Action	Cold Cathode Straight	Low	0.0E+00 mbar		
Open/Close Control	Open Close	Open Close					
			Ion Pump Arc 1	Dunn in u	7.2E-10 mbar	Front End 3 Vacuum State	an
Move Failure Status	Ok	0k		Running			
Move Failure Reset	Reset	Reset	Ion Pump Arc 2 Ion Pump Straight	Running	9.7E-10 mbar		
			for Fullip Straight	Interlock	1.0E-11 mbar	□ □ IR Front End Vacuum Sta	tus
Compressed Air							
Status <b>Ok</b>	Pressure	714 kPa					



×

Multipole Control - 1					×
	Vacuum Magnets & PS	Diagnostics Timing	Miscellaneous		
Multipol	e Control -	Sector 01 - (	Quadrupol	e Focussing	A1 🖕 🚰
Select by Sector			Select by Mag	inet	
01 02 03 04	05 06 07 08 09	10 11 12 13 14	QFA1 QDA1	QFB1 QFB2 QDA	2 QFA2
		· · · · · · · · · · · · · · · · · · ·	SFA1 SDA1	SDB1 SFB1 SDB	2 SDA2 SFA2
Magnet Status	1020-1-1		HCM1 VCM1	VCM2 HCM2 VCM	3 VCM4 HCM3
Temp Status <b>Ok</b>	LCW Status <b>0k</b>	LCW Flow Rate 14.08 1/min	SKQ1 SKQ2	!	
				-	
Power Supply Status	Remote	EPS Inhibit	Current	Voltage	
On	Remote	Enabled	135.69 Amps	37.60 Volts	
Temp Compensation	n +15 Volts	+5 Volts	-15 Volts	In Service	
-1.0 deg C	14.1 Volts	4.8 Volts	-13.8 Volts		
C Summary Interlo	ock Status				
AC Line Interloc		🔵 Ground Leak Interlo	ck Status 🛛 🜔	Magnet Flow Interlock	Status
😑 Fan Fault Interlo	ock Status	😑 Out Volt Interlock St	atus 🔘	Door Interlock Status	
Over Temp Inte	rlock Status	O Magnet Fault Interloo	ck Status 🛛 🔘	Rack LCW Interlock S	tatus
Control					
Active Set Point	135.732	Amps			
Set Point	Readba	ck	Sync		
	32 Amps	135.69 Amps		Ad	just Current
1.67	9 / m^2	1.679 / m^2		C Ad	just Strength
0.0 20.0		60.0 80.0	100.0 120.0	140.0 160	
S R 135.732	2	Current (Amps)		⊢ 135.732 <b>→ ◆</b>	
Power On	Power Off Fa	ult Reset		Cor	tinuous Apply
				06	Dec 06 15:26:42



Dipole Control


#### **Dipole Control**

Power Supply Status					
On/Off	Local / Remote	EPS Inhibit	Current	Voltage	
On	Remote	Enabled	611.5 Amps	756.0 V	olts
Ripple Current 1	Ripple Current 2	Ripple Current 3	Ground Current	Circuit Breaker	Inlet Water Temp
7.70 Amps	5.30 Amps	14.70 Amps	2.800 mA	Closed	24.8 deg C
O Summary Interloc	sk Status				
Phase		🔴 Water Pressure	e <b>C</b>	XFMR Fuse	
O DC Fuse		— О DCCT	Ō	) Water Leak	
😑 SCR Fuse		😑 Outlet Temp	0	) DC Voltage	
😑 SCR Temp		😑 EPS	C	) Filter Cap Ripple C	Current
🜔 XFMR Temp		🜔 PSS	C	) Breaker Trip	
🜔 Choke Temp		😑 Ground	C	) Breaker Open	
😑 Water Flow		🜔 Door	C	Emergency Off Pro	essed
Control					
Active Set Point	611.3 Amps				
Set Point	Readback	Sync			
611.3 Amp	s 611.5	Amp s 📃			Adjust Current
3.038 Ge	V 3.03	9 GeV 🛛			🔿 Adjust Energy
0.0 10		300.0	400.0	500.0 E	;00.0 700.0
S R 611.3	200.0	Current (A			511.3 • E A
		Canonic (A	po)		
Power On	Power Off F	ault Reset		Г	Continuous Apply


Magnet Status —			
	Temp Status	LCW Status	LCW Flow Rate
SR01DM01	0k	0k	26.11 l/min
SR01DM02	0k	0k	25.31 l/min
SR02DM01	0k	0k	25.86 l/min
SR02DM02	0k	Ok	25.31 l/min
SR03DM01	0k	Ok	25.39 1/min
SR03DM02	0k	Ok	25.48 l/min
SR04DM01	0k	Ok	26.67 l/min
SR04DM02	0k	0k	24.70 l/min
SR05DM01	0k	0k	25.73 l/min
SR05DM02	0k	0k	25.08 l/min
SR06DM01	0k	0k	25.55 l/min
SR06DM02	0k	0k	26.19 l/min
SR07DM01	0k	0k	25.64 l/min
SR07DM02	0k	0k	25.22 l/min
SR08DM01	0k	0k	25.61 l/min
SR08DM02	0k	0k	25.81 l/min
SR09DM01	0k	0k	24.89 l/min
SR09DM02	0k	0k	25.77 l/min
SR10DM01	0k	0k	25.83 l/min
SR10DM02	0k	0k	26.58 l/min
SR11DM01	0k	0k	24.42 l/min
SR11DM02	0k	0k	25.64 l/min
SR12DM01	0k	0k	26.19 l/min
SR12DM02	0k	0k	25.66 l/min
SR13DM01	0k	0k	22.00 1/min
SR13DM02	Ok	0k	23.61 l/min
SR14DM01	0k	Ok	25.75 l/min
SR14DM02	Ok	0k	24.08 l/min



×










06 Dec 06 15:30:40






#### Beam Loss Monitor Control

Framework	* General	Vacuum	Magnets & PS	Diagnostics	Timing	Miscellane
-----------	-----------	--------	--------------	-------------	--------	------------

#### **Beam Loss Monitor Control**

Index	Modify	On	Off	On/Off	Counts	Sensor A	Sensor B	Mode	LOF	HIF	More
401	Modify	On	Off	ON	16	DISABLED	DISABLED				
402	Modify	On	Off	ON	0	DISABLED	DISABLED				
503	Modify	On	Off	ON	16	DISABLED	DISABLED				
104	Modify	On	Off	ON	0	DISABLED	DISABLED				
105	Modify	On	Off	ON	8	DISABLED	DISABLED				
106	Modify	On	Off	ON	8	DISABLED	DISABLED				
107	Modify	On	Off	ON	0	DISABLED	DISABLED				
208	Modify	On	Off	ON	0	DISABLED	DISABLED				
209	Modify	On	Off	OFF	3520	DISABLED	DISABLED				
310	Modify	On	Off	ON	0	DISABLED	DISABLED				
311	Modify	On	Off	ON	0	DISABLED	DISABLED				
312	Modify	On	Off	ON	0	DISABLED	DISABLED				
313	Modify	On	Off	ON	0	DISABLED	DISABLED				
414	Modify	On	Off	ON	0	DISABLED	DISABLED				









×

+

<del>له</del> 🖗

		Т	iming Control			¢
Trigger Control			Master Oscillator			
Injection Trigger	Setpoint	Status	Set Point	Readback	Sync	
injection ingger			499,670,328 Hz	499,670,328 Hz	+499 , 670 , 32	8 A
Stop Start	Stop	Stopped				
			-1.8 dBm	-1.8 dBm	-1.8	A
Start Bucket						
1 🔮 🔺 🗌	1	1	Trigger Phase			
			Set Point	Readback	Sync	
			0.0 mSec	0.0 mSec	+0.0	A
Fill Control						
Stop Continuous	Stop	Stop	L			
			Miscellaneous			
One Shot Pattern Fill			Beam Current	81.10 mA	Injection Inhibit	

**Timing Control** 



-

비비 Programmable Delay Generator Control - 1

Framework General Vacuum Magnets & PS Diagnostics Timing Miscellaneous

#### **Programmable Delay Generator Control - DLY\_1**

DLY_1 DLY_2	DLY_3	DLY_4	DLY_5	DLY_6	DLY_7	SR00PDG01
🖵 Channel A - Linac Rack 01 PB	1					
Delay Set Point		Delay Re	adback		Edit/Apply	
0.000,010,000,	000 s	0.000,01	0,000,000 s	+0.000	,010,000,00	0 🔺
Channel B - Linac Rack 01 PB:	2					
Delay Set Point		Delay Re	adback		Edit/Apply	
0.000,010,000,	000 s	0.000,01	0,000,000 s	+0.000	,010,000,00	0
Channel C - Linac Rack 01 PB	3					
Delay Set Point		Delay Re	adback		Edit/Apply	
0.000,020,000,	000 s	0.000,01	0,000,000 s	+0.000	,020,000,00	0
Channel D - Linac Rack 01 PB	4					
Delay Set Point		Delay Re	adback		Edit/Apply	
0.000,010,000,	000 s	0.000,02	0,000,000 s	+0.000	,010,000,00	0 4



×

-

🗢 💕

💵 Fill Pattern Monitor

Framework General Vacuum Magnets & PS Diagnostics

ets & PS Diagnostics Timing Miscellaneous

#### **Fill Pattern Monitor**

17		0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
1/	4	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	1/	4	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	1/	4	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	4
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	4	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	4	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	4
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	4	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	4	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	4
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	4	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0	0/	0
																							Be	am Curr	ent		8(	D.80 ı	nA
																					_		_				_		



06 Dec 06 15:40:41

X

- |

÷ 💣

۵

UH Personnel Safety System Monitor

Framework General

Vacuum Magnets & PS

Diagnostics Timing Miscellaneous

#### **Personnel Safety System Monitor**

Note: The colour scheme employed here is opposite to that used on the SAGE PSS Control Panel.

PSS Status			
PSS 1 Status	On Line	PSS 2 Status	On Line
Search Zones		Injection System	
Search Zone 1 Status	Enabled	Electron Gun	Enabled
Search Zone 2 Status	Enabled	Linac RF Modulator 1	Enabled
Search Zone 3 Status	Enabled	Linac RF Modulator 2	Enabled
Search Zone 4 Status	Enabled	Booster Injection Kicker Outputs	Enabled
Search Zone 5 Status	Enabled	Booster Magnet PSU Outputs	Enabled
Search Zone 6 Status	Enabled	Booster RF PSU Outputs	Enabled
		Booster Extraction PSU Outputs	Enabled

#### Storage Ring

Power Feed to Equipment Suite 1 Power Feed to Equipment Suite 2 Power Feed to Equipment Suite 3 Power Feed to Equipment Suite 5 Power Feed to Equipment Suite 5 Power Feed to Equipment Suite 7 Storage Ring RF Pwr Feed to Str Ring Dipole PSU

Master Shutters Enable Switch

Enabled
Enabled
Closed

Power Feed to Equipment Suite 9EnabledPower Feed to Equipment Suite 10EnabledPower Feed to Equipment Suite 11EnabledPower Feed to Equipment Suite 12EnabledPower Feed to Equipment Suite 13Enabled
Power Feed to Equipment Suite 11 Enabled Power Feed to Equipment Suite 12 Enabled
Power Feed to Equipment Suite 12 Enabled
Power Feed to Equipment Suite 13 Enabled
Power Feed to Equipment Suite 14 Enabled
Storage Ring Kicker Status Enabled
Storage Ring Septum Status Enabled





Plant Monitor									
ramework General Vacuum	Magnets & PS Diagno	stics Timing	Miscellaneous						_
			Plant N	Aonitoi	ſ				¢ (
- LCW Circuits									
Name	Pressure	Con	ductivity	Охуд	en Level	Tem	perature	Flow Rate	
Power Supplies Temp	635.70 kPa	5.2	26 uS/cm	:	L.OO ppb	24.	98 deg C	14.10 1/s	
Storage RF Temperature	360.53 kPa	6.1	15 uS/cm	200	5.00 ppb	24.	98 deg C	52.52 1/s	
Injection Temperature	652.43 kPa	3.7	78 uS/cm	3	L.38 ppb	25.3	16 deg C	22.85 1/s	
SR LCW Temperature	747.53 kPa	5.6	62 uS/cm		0.75 ppb	24.	98 deg C	44.92 1/s	
- Storarge Ring LCW Circuit - A	dditional								
Return Temperature	29.50	deg C		Heat Excha	inger 3 Control V	alve		23.05 %	
Heat Exchanger Outlet Tempe	erature 24.94	deg C		Heat Excha	inger 3 Tempera	lture	24.	92 deg C	
Trim Heater Control Valve		1.27 🕺		Heat Excha	inger 3 Tempera	ture Set Point	24.	92 deg C	
Trim Heater Temperature	24.98	deg C		Heat Excha	inger 4 Control V	'alve		73.09 %	
Trim Heater Temperature Set I	Point 25.00	deg C		Heat Excha	inger 4 Tempera	ture	24.	92 deg C	
				Heat Excha	inger 4 Tempera	ture Set Point	24.	95 deg C	
Tunnel Temperatures									
Name	Temperature	Name		Tem	perature	Name		Temperature	
Storage Ring	22.01 deg C	Storage Ri	ng	22.	L3 deg C	Booster Ri	ng Q3 & Q4	23.72 deg C	
Storage Ring	22.05 deg C	Storage Ri	na	21.9	98 deg C	Popolar Di	ng Q1 & Q2	23.61 deg C	
					so aeg c	DOOS(ELHI	nganaaz	20.01 acg c	
Storage Ring	22.01 deg C	Storage Ri	-		99 deg C	booster hi	ng qi tu qz	25.61 409 0	
Storage Ring Compressors	22.01 deg C	Storage Ri	-					25101 409 0	
	22.01 deg C		-				itatus	Air Pressure	
Compressors		- Air F	ng	21.9		S			
Compressors Name Access Doors	Status Running	- Air F	ng Pressure	21.9 Name		S	- itatus ning	Air Pressure 738 . 44 kPa	
Compressors Name Access Doors Air Handling Unit Heat Exchar	Status Running	Air F 805	Pressure	21 . s Name Controls	99 deg C	S	itatus ning Chilled Wa	Air Pressure 738 . 44 kPa	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name	Status <b>Running</b> ngers Control \	Air F 805 /alve	<sup>p</sup> ressure . <b>16 kPa</b> Tempera	21. : Name Controls sture	<b>99 deg C</b> Temp Set F	S Run Point	itatus ning Chilled Wa Name	Air Pressure 738.44 kPa ter	
Compressors Name Access Doors Air Handling Unit Heat Exchar	Status Running ngers Control V 1 63	Air F 805	Pressure .16 kPa Tempera 22.01	21.s Name Controls ature deg C	99 deg C Temp Set F 22.01 d	S Run Point Aleg C	tatus <b>ning</b> Chilled Wa Name Chilled Wat	Air Pressure 738 , 44 kPa ter er 01	
Compressors Name Access Doors Air Handling Unit Heat Exchai Name Air handling unit 1 - Controller Air handling unit 1 - Controller	Status Running ngers Control \ 1 63 2 61	Air F 805 (alve 8.55 % 81 %	Pressure .16 kPa Tempers 22.01 22.01	21.3 Name Controls ature deg C deg C	79 deg C TempSet F 22.01 d 22.00 d	S Run Point deg C deg C	tatus <b>ning</b> Chilled Wa Name Chilled Wat	Air Pressure 738.44 kPa ter	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller	Status Running ngers Control \ 1 63 2 61 1 88	Air F 805 Valve 8.55 %	Pressure .16 kPa Tempera 22.01 22.01 22.04	Aname Controls ature deg C deg C deg C	79 deg C TempSet F 22.01 d 22.00 d 22.04 d	S Run Point Reg C Reg C Reg C	tatus <b>ning</b> Chilled Wa Name Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 1 - Controller Air handling unit 2 - Controller	Status Running ngers Control \ Contr	Air F 805 4Ive 8.55 % 81 % 8.42 %	Pressure .16 kPa Tempers 22.01 22.01	Anne Controls ature deg C deg C deg C deg C	79 deg C TempSet F 22.01 d 22.00 d	S Run Point deg C deg C deg C deg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 1 - Controller Air handling unit 2 - Controller Air handling unit 2 - Controller	Status Running ngers Control V Contr	Air F 805 4 ve 3.55 % 81 % 3.42 %	Pressure .16 kPa Tempera 22.01 22.01 22.04 22.04	Anme Controls ature deg C deg C deg C deg C deg C deg C	79 deg C TempSet f 22.01 d 22.04 d 22.04 d	S Run Point deg C deg C deg C deg C deg C deg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C er 02	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 1 - Controller Air handling unit 2 - Controller Air handling unit 2 - Controller Air handling unit 3 - Controller	Status  Running  ngers  Control V  Control V	Air F 805 (alve 8.55 % 81 % 8.42 % 9.46 % 72 %	Pressure .16 kPa Tempera 22.01 22.01 22.04 22.04 22.04	Aure Adeg C deg C deg C deg C deg C deg C deg C deg C	79 deg C TempSetF 22.01 d 22.04 d 22.00 d 22.00 d 22.00 d	S Run Point deg C deg C deg C deg C deg C deg C deg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C er 02	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 2 - Controller Air handling unit 2 - Controller Air handling unit 3 - Controller Air handling unit 3 - Controller Air handling unit 3 - Controller	Status Running ngers Control \ Contr	Air F 805 (alve 8.55 % 8.42 % 9.46 % 72 % 5.95 %	Pressure .16 kPa Tempera 22.01 22.01 22.04 22.04 22.01 22.01	Aure Controls ature deg C deg C deg C deg C deg C deg C deg C deg C deg C	79 deg C Temp Set F 22.00 d 22.04 d 22.00 d 22.01 d 22.01 d 22.01 d 22.01 d	S Point deg C deg C deg C deg C deg C deg C deg C deg C deg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C er 02	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 2 - Controller Air handling unit 2 - Controller Air handling unit 3 - Controller Air handling unit 4 - Controller	Status Running ngers Control V Contr	Air F 805 (alve 3.55 % 3.42 % 9.46 % 1.72 % 5.95 % 5.80 %	Pressure .16 kPa Tempera 22.01 22.04 22.04 22.04 22.01 22.01 22.01 22.13	Aure Controls ature deg C deg C deg C deg C deg C deg C deg C deg C deg C deg C	79 deg C Temp Set F 22.00 d 22.00 d 22.00 d 22.01 d 22.01 d 22.01 d 22.00 d 22.01 d 22.00 d	Point Run deg C deg C deg C deg C deg C deg C deg C deg C deg C deg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C er 02	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 2 - Controller Air handling unit 2 - Controller Air handling unit 3 - Controller Air handling unit 3 - Controller Air handling unit 3 - Controller Air handling unit 4 - Controller Air handling unit 4 - Controller	Status Running ngers Control V Contr	Air F 805 (alve 3.55 % 3.42 % 9.46 % 3.72 % 5.95 % 5.80 % 3.44 %	Pressure .16 kPa Tempera 22.01 22.04 22.04 22.04 22.01 22.01 22.13 22.13 21.98	Aure Controls ature deg C deg C	79 deg C Temp Set F 22.01 d 22.04 d 22.00 d 22.01 d 22.00 d 22.01 d 22.00 d 22	Point Rum Aleg C Aleg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C er 02	
Compressors Name Access Doors Air Handling Unit Heat Exchar Name Air handling unit 1 - Controller Air handling unit 2 - Controller Air handling unit 2 - Controller Air handling unit 3 - Controller Air handling unit 3 - Controller Air handling unit 3 - Controller Air handling unit 4 - Controller Air handling unit 4 - Controller Air handling unit 5 - Controller	Status Running ngers Control V Contr	Air F 805 (alve 3.55 % 81 % 3.42 % 0.46 % 72 % 5.95 % 5.80 % 3.44 % 3.08 %	Pressure .16 kPa Tempera 22.01 22.04 22.04 22.04 22.01 22.01 22.13 22.13	Name Controls	79 deg C Temp Set F 22.01 d 22.00 d 22.01 d 22.01 d 22.01 d 22.01 d 22.01 d 22.01 d 22.01 d 22.01 d 22.01 d	Point Run deg C deg C	tatus ning Chilled Wa Name Chilled Wat 6.2 Chilled Wat	Air Pressure 738.44 kPa ter er 01 27 deg C er 02	



#### Facility Status Monitor <u>http://www.synchrotron.vic.gov.au</u> Static version <u>http://vbl.synchrotron.vic.gov.au/fsm/</u> Java

